


DO NOT SCALE. IF IN DOUBT ASK. ALL DIMENSIONS IN MILLIMETERS UNLESS STATED OTHERWISE.



Lead Soakers.
Code 4 lead is sufficient for normal exposures. Use code 5 lead for severer exposures, and consider clipping down tiles in coastal areas.

Plain clay roof tiles.

50mm.

38x25 treated sw tile batten.

38x25 treated sw counterbatten.

Thermoliner decoupled lining subframe (factory fitted).

Draughtstrip.

Timber lining (by contractor).

25mm WBP ply packer of same height as counterbattens. This sits upon treated sw packer of same height as insulation. Fix both strongly to the structural support rafters.

Roofing felt
Batten is bearer for insulation here.

Rigid bat insulation over vapour barrier, on rafters. The vapour barrier terminates in the Thermoliner slot for the lining board at the rooflight.

Timber packers bring lining board out to correct position to fit into Thermoliner slot. Insert insulation wherever there is space.

Structural support members.

Architrave (by contractor).

The Metal Window Company Limited
Unit 8, Wychwood Busines Centre
Milton Road
Shipton-Under-Wychwood
Oxon OX7 6XU

Telephone: 01993-830-613
Fax: 01993-831-066
Email: info@metalwindow.co.uk
Web: www.metalwindow.co.uk

Please note that this drawing does not constitute a structural support proposal. Sufficiency of structural supports to be checked by rooflight purchaser's structural consultant.

Drawing Ref/No. 11062-27

Title. CLAY TILE JAMB DETAIL
WARM ROOF CONSTRUCTION

Scale. N.T.S Date:01/10/01

Drawn By: PK

Checked By:PK

Revision No.

The information contained within this drawing is Copyright & Design right of THE METAL WINDOW COMPANY LIMITED.